

**ASSET MANAGEMENT
DEPARTMENT**

Facilities Maintenance Policy
and Procedures Manual

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



ASSET MANAGEMENT

FACILITIES MAINTENANCE POLICY AND PROCEDURES MANUAL

Updated – 17/12/2021

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



Contents

I. SECTION I: INTRODUCTION.....	4
I.1 INTRODUCTION	4
I.2 LEVELS OF MAINTENANCE AND RELATED COST FACTORS.....	5
I.2.1 Building Use	5
I.2.2 Building and Equipment Design.....	6
I.2.3 Advances in technology	6
I.2.4 Condition of existing Campus buildings.....	6
I.2.5 Service standards.....	6
I.2.6 Operational considerations (preventive maintenance)	7
II. SECTION II: GENERAL MAINTENANCE METHODS.....	7
III. SECTION III: CAMPUS MAINTENANCE SCOPES OF WORK.....	9
III.1 MAINTENANCE SERVICE CONTRACT'S SCOPES OF WORK.....	9
III.1.1. Low Voltage.....	9
III.1.2 Transformer and MV Switch Board	10
III.1.3 External Lighting.....	11
III.1.4 Standby Generator	12
III.1.5 Uninterruptible Power Supply (UPS)	13
III.1.6 Building Management System.....	14
III.1.7 Closed-circuit television (CCTV).....	15
III.1.8 Distribution Board.....	15
III.1.9 Earthing and Lightning	16
III.1.10 Split Air Conditioning	16
III.1.11 Variable Refrigerant Volume Air conditioning (VRV).....	17
III.1.12 Precision Air Conditioning (PAC).....	18
III.1.13 Fire Extinguisher.....	18
III.1.14 Fire Fighting	19
III.1.15 Fresh Water Pump	20

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.16 Sum Pump	20
III.1.17 Wastewater Treatment.....	21
III.1.18 Heat pump.....	22
III.1.19 Ventilation Fan.....	23
III.1.20 Access Control.....	24
III.1.21 Fire Alarm	25
III.1.22 Public Address.....	25
III.1.23 FM 200 & CO2.....	26
III.1.24 Telephone.....	26
III.1.25 Roller Shutter door	26
III.1.26 Liquefied Petroleum Gas	27
III.2 PREVENTIVE MAINTENANCE PROGRAM	27

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



I. SECTION I: INTRODUCTION

I.1 INTRODUCTION

Asset Management is the department responsible for the maintenance and management of all facilities at BUV. We adopt a proactive management approach to provide and maintaining a safe, orderly and respectful learning environment which will contribute to student and staff's best learning and working experience and achievements.

With BUV's commitments to bring a world-class campus facilities and services and to provide a happy, healthy, safe, and internationally oriented campus life for its students and community, it is important that any issues regarding the appropriate management of facilities and campus Health and Safety are resolved on an urgent basis. BUV seek regular feedback from key stakeholders, and any matters arising are discussed in weekly Senior Leadership Team (SLT) meetings by the Chief Operating Officer (COO) and Chief Academic Officer (CAO). Any issues and actions raised in these meetings are noted for follow up by the appropriate body. For issues and actions related to the management of any BUV facilities, Asset Management then leads in the creation of an action plan to address the issue which include identifying root causes, proposing solutions in consideration of costs and budgets, and seeking approval for rectification. Once approval has been gained, Asset Management will lead the implementation of the solution.

Frequent reviews of FD service performance are jointly discussed by all SLT members. The FD seeks to take a creative and innovative approach in proactively reviewing the ability of facilities to meet the needs of users, seeking solutions to any potential issues identified, and project managing any required implementations. This is a central tenet of the strategy of the FD, and contributes significantly to the excellence of University operations.

On an operational level, it should be noted that there are some property management and maintenance areas in which contracted services supplement and/or have major responsibilities for building and/or equipment maintenance. In those cases where contracted services have traditionally been utilised, such services have proven to be cost effective. However, the focus of Asset Management will remain as follows:

- Focus on Campus environmental issues in keeping with a safe learning/teaching environment.
- To ensure proper training for Campus personnel on the procedure to provide timely and efficient maintenance for all Campus buildings and grounds.

- To provide the means to save energy and improve the operating efficiency of all Campus facilities and to ensure proper air quality controls county wide.

The overall objective of Asset Management is to proactively manage and maintain, throughout its expected useful life, the interior and exterior of university buildings, the grounds, and the roadways, and all fixed and moveable equipment through preventive maintenance and repairs and being innovative in addressing potential and emerging issues. Further, this objective is specifically intended to provide:

1. High-quality and serviceable facilities (through a proactive approach considering risk management)
2. Buildings and their components that function safely and at top efficiency.
3. Facilities and equipment that minimise the possibility of fires, accidents, and safety hazards.
4. Continuous use of facilities without disruptions to the educational program.
5. Protection of public property through proper planning, scheduling, and preventive maintenance.
6. Quality management of maintenance projects and tasks.
7. Conservation of energy through utilisation of the latest technology and energy conservation measures.

I.2 LEVELS OF MAINTENANCE AND RELATED COST FACTORS

There are a variety of factors associated with the desired level of Campus building maintenance that relate directly to the availability of resources. These include age of facility, age of equipment, available manpower, budget, and facility use beyond that of the regular Campus Day. To assess the impact of required Campus building maintenance efforts, the following factors are presented:

I.2.1 Building Use

Campus buildings may require various levels of maintenance due to the varied use of the facilities. The maintenance effort and cost for Campus facilities can often be traced to the extent of the facilities use, the type of facilities use, an effective building supervisor.

Vandalism during occupied and unoccupied hours also places an additional cost burden on the Campus maintenance program.

I.2.2 Building and Equipment Design

Another major factor that influences equipment and building maintenance is the design of the Campus facility. Facility designers can conserve public funds by incorporating design characteristics consistent with maintenance efficiency and longevity. During the design process, materials and equipment selected should demonstrate characteristics of:

- Design simplicity and equipment accessibility as related to performing repairs and preventive maintenance.
- Quality and maintainability.
- Ease of component replacement and repair parts availability.
- Maximum operating efficiency of all mechanical components and maximum energy efficiency of all mechanical/electrical systems.

I.2.3 Advances in technology

New technology and energy saving measures related to building equipment and components need to be carefully considered and incorporated into the building maintenance program to insure a more cost-effective level of maintenance. These new technological advances may require the development of revised maintenance and operations procedures and may reduce operating costs. While such advances may show a first time or one time increase in the maintenance or construction budget, there may be a significant long-term decrease in the plant operations budget.

I.2.4 Condition of existing Campus buildings

The condition of existing Campus facilities needs to be considered as well as frequency of use of facilities beyond the normal Campus Day when evaluating the overall maintenance effort. These factors create a significant impact to the plant maintenance program to provide adequate funding, staffing and effective building maintenance.

I.2.5 Service standards

Maintenance service standards for university facilities are best established through adequate program administration and supervision, effective employee selection and training, and maintaining employee performance within the organisation. The overall scope necessary for adequate plant maintenance procedures and services is highlighted in the charts shown in Section II and

Section III. These are intended to reflect scheduled service standards and routine preventive maintenance procedures.

1.2.6 Operational considerations (preventive maintenance)

Asset Management is important in assessing overall maintenance levels and determining costs associated with building maintenance.

Asset Management has the prime responsibility for building/equipment maintenance based on specific areas of responsibilities. It should be noted that there are some maintenance areas in which contracted services supplement or have major responsibilities for building and/or equipment maintenance. In those cases where contracted services have traditionally been utilised, such services have proven to be cost effective.

In summary, all of the aforementioned factors have a direct impact on establishing a cost-effective maintenance program that meets the requirements of today's educational environment.

II. SECTION II: GENERAL MAINTENANCE METHODS

There are three (3) methods for performing required building and equipment maintenance that have proven to be cost-effective and are presently being utilised in the British University Vietnam. They include:

- Assignment of Technical Team to perform daily maintenance tasks and preventive maintenance.
- Utilisation of maintenance service contracts.

The Technical Team provides the following services:

- Emergency response to power failures, plumbing, heat pump, and air conditioning failures.
- Electrical, plumbing, HVAC service and minor repairs
- Grounds maintenance, mowing, landscaping, etc.
- Minor building modifications
- Preventive maintenance

Asset Management also is responsible for contracted services in which contracted services supplement or have major responsibilities for building and/or equipment maintenance. These would include:

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



No	System	Maintenance Frequency
1	Low Voltage	Yearly
2	Transformer and MV Switch Board	Yearly
3	External Lighting	Semi - Yearly
4	Standby Generator	Quarterly
5	Uninterruptible Power Supply (UPS)	Quarterly
6	Building Management System	Semi - Yearly
7	Closed-circuit television (CCTV)	Semi - Yearly
8	Distribution Board	Semi - Yearly
9	Earthing and Lightning	Yearly
10	Split Air Conditioning	Semi - Yearly
11	Variable Refrigerant Volume Air conditioning (VRV)	Semi - Yearly
12	Precision Air Conditioning (PAC)	Quarterly
13	Fire Extinguisher	Semi - Yearly
14	Fire Fighting	Semi - Yearly
15	Fresh Water Pump	Quarterly
16	Sum Pump	Quarterly
17	Wastewater Treatment	Quarterly
18	Heat Pump	Quarterly
19	Ventilation Fan	Semi - Yearly
20	Access Control	Semi - Yearly
21	Fire Alarm	Semi - Yearly
22	Public Address	Semi - Yearly
23	FM 200 & CO2	Semi - Yearly
24	Telephone	Semi - Yearly
25	Roller Shutter door	Quarterly
26	Liquefied Petroleum Gas	Semi - Yearly

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III. SECTION III: CAMPUS MAINTENANCE SCOPES OF WORK

III.1 MAINTENANCE SERVICE CONTRACT'S SCOPES OF WORK

III.1.1. Low Voltage

MAINTENANCE SCOPE OF WORKS FOR LOW VOLTAGE					
No	Description of work	Routine			
		Monthly	Quarterly	Semi Yearly	Yearly
I	Switch board				
1	Thermal scanning for low voltage switch board and all connection (scan all positions especially for bus bar, but report for typical and hottest positions only).				<input type="checkbox"/>
2	General inspection for overheating all connection.				<input type="checkbox"/>
3	General inspection for damage, noise or other abnormal phenomenon.				<input type="checkbox"/>
4	Check pilot light, relays and switch				<input type="checkbox"/>
5	Check function of ATS				<input type="checkbox"/>
6	Check ACB interlock				<input type="checkbox"/>
7	Check all the ACB & MCCB terminal				<input type="checkbox"/>
8	Check the mechanical function of the equipment MCCB, MCB				<input type="checkbox"/>
9	Check and the control wire				<input type="checkbox"/>
10	Inspect and clean the switchboards.				<input type="checkbox"/>
11	Power analysis (U, I, PF, THDv, THDi) to detect any abnormal phenomenon. Chưa bao gồm trong báo giá)				<input type="checkbox"/>
12	Cleaning and lubrication for the moving parts.				<input type="checkbox"/>
13	Check all the terminals and cable connectors, re-tightening by standard torque.				<input type="checkbox"/>
14	Check earthing system of LV panel system.				<input type="checkbox"/>
II	Test ACB				
1	Insulation resistance testing for ACB.				<input type="checkbox"/>
2	Contact resistance testing for ACB.				<input type="checkbox"/>
3	Protection function testing for ACB.				<input type="checkbox"/>
III	Capacitor panel				
1	Check status of controller				<input type="checkbox"/>
2	Check control cable and control circuit status				<input type="checkbox"/>
3	Check earthing system at panel.				<input type="checkbox"/>
4	Functional test of capacitor controller.				<input type="checkbox"/>
5	Examine the contactors condition and function.				<input type="checkbox"/>
6	General inspection for overheating all connection.				<input type="checkbox"/>
7	Check the reactor for physical damaged				<input type="checkbox"/>
8	Inspect and clean the switchboards.				<input type="checkbox"/>
9	Inspect and measure capacitance of each capacitor. Measure the resistance of the filter reactor				<input type="checkbox"/>
10	Re-tightening all connections by standard torque.				<input type="checkbox"/>
11	Check ventilation fan of capacitor cubic.				<input type="checkbox"/>
IV	UPS of LV switchboards (if any)				
1	Measure the input voltage of UPS.				<input type="checkbox"/>
2	Measure the output voltage of UPS.				<input type="checkbox"/>
3	On-load test UPS.				<input type="checkbox"/>
V	Issue technical report with advices (if any)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.2 Transformer and MV Switch Board

MAINTENANCE SCOPE OF WORKS FOR POWER TRANSFORMER AND MV SWITCHBOARD SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I Switch gear					
1	General inspection for sight of overheating, damage, arc discharge, unusual noise or other defects.				<input type="checkbox"/>
2	Thermal scanning for MV switch board.				<input type="checkbox"/>
3	Check meter, pilot light and control wire				<input type="checkbox"/>
4	Check circuit breaker interlock				<input type="checkbox"/>
5	Cleaning and lubrication for the moving parts.				<input type="checkbox"/>
6	Cleaning of medium-voltage rooms, transformers, cleaning of electrical cabinets, equipment				<input type="checkbox"/>
7	Check earthing of MV panel.				<input type="checkbox"/>
II Testing switch gear					
1	Test insulation of MV switch gears, MV busbar.				<input type="checkbox"/>
2	Measure main contact resistance of MV switch gear.				<input type="checkbox"/>
3	Test CT/PT				<input type="checkbox"/>
4	Test power-frequency withstand for MV switch gear and busbar.				<input type="checkbox"/>
III UPS of MV switchboards (if any)					
1	Measure the input voltage of UPS.				<input type="checkbox"/>
2	Measure the output voltage of UPS.				<input type="checkbox"/>
IV Power transformer					
1	Check all parameters of the unit: voltage, frequency and current input and output.				<input type="checkbox"/>
2	Inspect for any abnormal noise, vibration, arc discharge and overheat.				<input type="checkbox"/>
3	Thermal scanning for transformer.				<input type="checkbox"/>
4	Check, clean all of the bushing, bus-bar of transformer.				<input type="checkbox"/>
5	Check oil leakage				<input type="checkbox"/>
6	Check the protection relays of transformer				<input type="checkbox"/>
7	Check and retightening the control circuit.				<input type="checkbox"/>
8	Check and clean ventilation fans.				<input type="checkbox"/>
9	Check the protection relays of transformer, functions testing (nếu có).				<input type="checkbox"/>
10	Check all measuring and indicating devices. Re-adjust zero if necessary.				<input type="checkbox"/>
11	Check all of terminals and cable connectors, re-tightening by standard torque.				<input type="checkbox"/>
12	Measure earthing resistance of transformer.				<input type="checkbox"/>
13	Check for any corrosion and touch up painting.				<input type="checkbox"/>
V Testing transformer					
1	Test insulation of transformer and MV cable.				<input type="checkbox"/>
2	No-load test.				<input type="checkbox"/>
3	Test ratio and vector group.				<input type="checkbox"/>
4	Test DC winding resistance of transformer.				<input type="checkbox"/>
5	Test high voltage power-frequency withstand.				<input type="checkbox"/>
VI Protection relay					
1	Check status of relay.				<input type="checkbox"/>
2	Check relay alarm/ trip history				<input type="checkbox"/>
3	Check setting function of relay.				<input type="checkbox"/>
4	Check control cable and control circuit status				<input type="checkbox"/>
5	Over current protection test.				<input type="checkbox"/>
6	Voltage protection test.				<input type="checkbox"/>
VII Issue report with technical comment and advice (if any)					
					<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.3 External Lighting

MAINTENANCE SCOPE OF WORKS FOR EXTERNAL LIGHTING SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Check operation status of control panel.			<input type="checkbox"/>	
2	Adjustment the time (auto on-off) of the system.			<input type="checkbox"/>	
3	Check status of lighting pole.			<input type="checkbox"/>	
4	Check connection status of lamp.			<input type="checkbox"/>	
5	Check status of supply power cable for lamp.			<input type="checkbox"/>	
6	Replace lamp, if necessary (during maintenance, material will be additional quote)			<input type="checkbox"/>	
7	Clean for lamp.			<input type="checkbox"/>	
8	Issue report.			<input type="checkbox"/>	

ASSET MANAGEMENT**DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.4 Standby Generator

MAINTENANCE SCOPE OF WORKS FOR STAND-BY GENERATOR					
No	Description of work	Routine			
		Monthly	Quarterly	Semi Yearly	Yearly
A Engine					
1	Record operated hour meter.		<input type="checkbox"/>		<input type="checkbox"/>
2	Record pressure of lubricated oil when gen-set operating.		<input type="checkbox"/>		<input type="checkbox"/>
3	Record coolant water temperature.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check for abnormal vibration.		<input type="checkbox"/>		<input type="checkbox"/>
5	Check tightness of mountings (if necessary).				<input type="checkbox"/>
6	Check speed sensor (if necessary).				<input type="checkbox"/>
7	Check actuator (if necessary).				<input type="checkbox"/>
8	Clean the engine body and the generator room.		<input type="checkbox"/>		<input type="checkbox"/>
B Lubricating					
1	Check for leakages.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check lube oil level (when engine stop).		<input type="checkbox"/>		<input type="checkbox"/>
3	Check oil pressure sensor.		<input type="checkbox"/>		<input type="checkbox"/>
C Coolant					
1	Change coolant water.				<input type="checkbox"/>
2	Change water filter.				<input type="checkbox"/>
3	Check for leaks.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check encrust.		<input type="checkbox"/>		<input type="checkbox"/>
5	Check flexible connections.		<input type="checkbox"/>		<input type="checkbox"/>
6	Check water coolant level.		<input type="checkbox"/>		<input type="checkbox"/>
7	Check radiator.		<input type="checkbox"/>		<input type="checkbox"/>
8	Check operation of coolant heater (if any).		<input type="checkbox"/>		<input type="checkbox"/>
9	Check belt condition & tension of fan.				<input type="checkbox"/>
10	Grease fan hub & pulley bearings (if necessary).				<input type="checkbox"/>
11	Check coolant temperature sensor.		<input type="checkbox"/>		<input type="checkbox"/>
12	Clean cooling system.		<input type="checkbox"/>		<input type="checkbox"/>
D Induction air					
1	Check air filter condition.		<input type="checkbox"/>		<input type="checkbox"/>
2	Replace air filter (If necessary).				<input type="checkbox"/>
3	Check intake air system.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check pipe and connections.		<input type="checkbox"/>		<input type="checkbox"/>
E Daily fuel tank and fuel system					
1	Check for leakage.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check hoses and connections.		<input type="checkbox"/>		<input type="checkbox"/>
3	Check fuel level.		<input type="checkbox"/>		<input type="checkbox"/>
4	Insulation resistance test for motor.				<input type="checkbox"/>
5	Check fuel supply and return pump operation.		<input type="checkbox"/>		<input type="checkbox"/>
6	Change fuel filter elements (every 250 hours running or 12 months).				<input type="checkbox"/>
7	Check/ Drain sediment in fuel tank daily.		<input type="checkbox"/>		<input type="checkbox"/>
8	Check oil level in automatic mode				<input type="checkbox"/>
9	Check oil level in manual mode		<input type="checkbox"/>		<input type="checkbox"/>
F Main fuel storage tank					
1	Check for leakage.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check fuel level on indicator (if any).		<input type="checkbox"/>		<input type="checkbox"/>
3	Check air ventilation pipe.		<input type="checkbox"/>		<input type="checkbox"/>
G Exhaust					
1	Check for leakages.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check outlet & exhaust system.		<input type="checkbox"/>		<input type="checkbox"/>
3	Check the working of turbocharger.				<input type="checkbox"/>
4	Check for abnormal vibration.				<input type="checkbox"/>
H Electrical					
1	Check battery charging alternator belt conditions & tension (if necessary).		<input type="checkbox"/>		<input type="checkbox"/>
2	Check batteries and battery charger condition, clean and tighten connectors.		<input type="checkbox"/>		<input type="checkbox"/>
3	Measure voltage battery when gen-set not operating.		<input type="checkbox"/>		<input type="checkbox"/>
4	Measure voltage battery when gen-set cranking.		<input type="checkbox"/>		<input type="checkbox"/>
5	Measure and record voltage and internal resistance of each batteries.		<input type="checkbox"/>		<input type="checkbox"/>
6	Tighten connectors .				<input type="checkbox"/>
I Alternator					
1	Clean windings, tighten connector.				<input type="checkbox"/>
2	Check excitation windings.				<input type="checkbox"/>
3	Check/ grease bearings (if necessary).				<input type="checkbox"/>
4	Continuity test and check earth resistance.				<input type="checkbox"/>
K Control box & electrical auxiliaries					
1	Vacuum/clean the switchboard.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check condition of meters and indication devices & auxiliaries.		<input type="checkbox"/>		<input type="checkbox"/>
3	Tighten connectors.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check the emergency shutdown functions.		<input type="checkbox"/>		<input type="checkbox"/>
5	Check working of AVR (if necessary).				<input type="checkbox"/>
L Air circuit breaker					
1	Visual check for condition of ACB if overheating.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check/tighten connection (if necessary).		<input type="checkbox"/>		<input type="checkbox"/>
M Collecting data when gen-set on load (as actual working situation)					
1	No load running test		<input type="checkbox"/>		<input type="checkbox"/>
2	Check function changeover of ATS.		<input type="checkbox"/>		<input type="checkbox"/>
3	Voltage		<input type="checkbox"/>		<input type="checkbox"/>
4	Current		<input type="checkbox"/>		<input type="checkbox"/>
5	HZ		<input type="checkbox"/>		<input type="checkbox"/>
6	Oil pressure		<input type="checkbox"/>		<input type="checkbox"/>
7	Water temperature		<input type="checkbox"/>		<input type="checkbox"/>
N Replace equipment periodically					
1	Change lube oil (every 250hrs running or 12 months).				<input type="checkbox"/>
2	Replace filters (every 250hrs running or 12 months).				<input type="checkbox"/>
3	Replace cooling water (every 250hrs running or 12 months).				<input type="checkbox"/>
0	Report with technical advice (if any)		<input type="checkbox"/>		<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.5 Uninterruptible Power Supply (UPS)

MAINTENANCE SCOPE OF WORKS FOR UPS					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Preliminary checks				
1	Check alarm history of UPS (if any).		<input type="checkbox"/>		
2	Check ventilation fan status		<input type="checkbox"/>		
4	Check for corrosion on all the terminal and cable.		<input type="checkbox"/>		
5	Check battery		<input type="checkbox"/>		
6	Checks tighten of connection.		<input type="checkbox"/>		
7	Clean UPS.		<input type="checkbox"/>		
8	With customer approval, perform test unit transfer and battery discharge.		<input type="checkbox"/>		
II	Check & record calibration				
1	Supply Voltage		<input type="checkbox"/>		
2	Battery Voltage		<input type="checkbox"/>		
3	Measure and record internal resistance of each batteries (if possible).		<input type="checkbox"/>		
4	Output voltage.		<input type="checkbox"/>		
III	General checks		<input type="checkbox"/>		
1	Check room temperature status.		<input type="checkbox"/>		
2	Check status operation of air-con.		<input type="checkbox"/>		
3	Check status operation of ventilation fan.		<input type="checkbox"/>		
IV	Issue report and advices (if any)		<input type="checkbox"/>		

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.6 Building Management System

MAINTENANCE SCOPE OF WORKS FOR BMS SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
A BMS Workstaion					
1	Check operation status Hardware of workstation			<input type="checkbox"/>	
2	Check operation status Software of workstation			<input type="checkbox"/>	
3	Check network connections of BMS system			<input type="checkbox"/>	
4	Check function of system (function in use)			<input type="checkbox"/>	
5	Check auto program, time schedule of system			<input type="checkbox"/>	
6	Check system alarm, after that clear it or inform solution to clear it			<input type="checkbox"/>	
7	Make backup of software before maintenance			<input type="checkbox"/>	
8	Cleaning equipments			<input type="checkbox"/>	
B Third party integrator or high level interface system					
1	Check communication line with BMS system, recommendation (if any)			<input type="checkbox"/>	
2	Compare the value of integrator equipment and display on the BMS			<input type="checkbox"/>	
C Direct digital control (DDC)					
1	Check all equipment inside the DDC panel: Power indicator, Power supply unit, Battery, controller devices			<input type="checkbox"/>	
2	Check operation status of DDC controller			<input type="checkbox"/>	
3	Check all signal are monitor or controlled by DDC controller			<input type="checkbox"/>	
4	Check all termination and re-tighten if any loose connection			<input type="checkbox"/>	
5	Cleaning equipments			<input type="checkbox"/>	
D Field device or point to point connection					
D1 Control or monitor device of HVAC system					
1	Check status temperature & humidity sensor outside of the building			<input type="checkbox"/>	
2	Check status temperature sensor inside the room, water pipe, air duct			<input type="checkbox"/>	
5	Check status pressure sensor inside the water pipe, air duct, stair case...			<input type="checkbox"/>	
6	Check status smoke sensor inside air duct			<input type="checkbox"/>	
7	Check status CO or CO ₂ concentration sensor.			<input type="checkbox"/>	
8	Check operation status of air pressure switch, difference pressure sensor			<input type="checkbox"/>	
9	Check measurement status of flow meter.			<input type="checkbox"/>	
10	Check operation status of all motorize valve of Chiller, PAU, AHU, FCU...			<input type="checkbox"/>	
11	Check operation status of all motorize damper of air duct system			<input type="checkbox"/>	
12	Check all connection from Chiller, Pump, Fan to BMS system			<input type="checkbox"/>	
D2 Control or monitor device of Fire Alarm (FA) system					
1	Check signal connect between FA system and BMS			<input type="checkbox"/>	
2	Check interlock signal of BMS system in the fire mode			<input type="checkbox"/>	
D3 Control or monitor device of Power system					
1	Check signal status of ACB, MCCB... on the BMS monitor			<input type="checkbox"/>	
2	Check measuring from power meter connect with BMS system			<input type="checkbox"/>	
3	Check all connection from generator system to BMS system			<input type="checkbox"/>	
4	Check all connection from UPS system to BMS system			<input type="checkbox"/>	
D4 Control or monitor device of Lighting system					
1	Check signal status of lighting display on the BMS monitor			<input type="checkbox"/>	
2	Check control ability from BMS monitor to lighting line			<input type="checkbox"/>	
D5 Control or monitor device of remain system					
1	Check signal status of equipment display on the BMS monitor			<input type="checkbox"/>	
2	Check control ability from BMS monitor			<input type="checkbox"/>	
3	Submit maintenance report with recommendation (if any)			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.7 Closed-circuit television (CCTV)

MAINTENANCE SCOPE OF WORKS FOR CCTV SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Carry out a visual inspection of all major components (including cabling and connections) for signs of deterioration or damage and report to client as necessary.			<input type="checkbox"/>	
2	Examine supporting brackets.			<input type="checkbox"/>	
3	Check physical condition of cameras and housings.			<input type="checkbox"/>	
4	Check that field of view is correct.			<input type="checkbox"/>	
5	Check that all camera bracket fittings and clamping bolts are tight.			<input type="checkbox"/>	
6	Check that lenses are correctly focused.			<input type="checkbox"/>	
7	Check operation of auto-iris lenses as appropriate.			<input type="checkbox"/>	
8	Clean housing windows as necessary.			<input type="checkbox"/>	
9	Check operation of infrared units. (If any)			<input type="checkbox"/>	
10	Check physical condition and cable connections.			<input type="checkbox"/>	
11	Check operation of controls and adjust for best picture.			<input type="checkbox"/>	
12	Check operation of keyboard controllers.			<input type="checkbox"/>	
13	Check time/ date settings and adjust if necessary.			<input type="checkbox"/>	
14	Check & clean hard disk recorder, card, LCD			<input type="checkbox"/>	
15	Check proper operation of UPS (If any)			<input type="checkbox"/>	
16	Complete maintenance report and discuss work conducted with client.			<input type="checkbox"/>	

III.1.8 Distribution Board

MAINTENANCE SCOPE OF WORKS FOR DISTRIBUTION BOARD					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	General inspection for damage, unusual noise of all connections, equipment or other abnormal phenomenon.			<input type="checkbox"/>	
2	Thermal scanning for electrical cabinets			<input type="checkbox"/>	
3	Check the abnormal colour of wires and cables at connection point.			<input type="checkbox"/>	
4	Check all connection and re-tighten connection.			<input type="checkbox"/>	
5	Check switches, pilot lights and selectors.			<input type="checkbox"/>	
6	Check earthing connection of panel.			<input type="checkbox"/>	
7	Clean inside and outside of panel.			<input type="checkbox"/>	
8	Issue report and advices (if any).			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.9 Earthing and Lightning

MAINTENANCE SCOPE OF WORKS FOR EARTHING AND LIGHTNING SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Check the copper tape status				<input type="checkbox"/>
2	Line check for copper tape.				<input type="checkbox"/>
3	Visual check lightning rod.				<input type="checkbox"/>
4	Measure earth resistance.				<input type="checkbox"/>
5	Check rusty, clean & retighten connections				<input type="checkbox"/>
6	Issue report with advice (if any).				<input type="checkbox"/>

III.1.10 Split Air Conditioning

MAINTENANCE SCOPE OF WORKS PARKAGE AIR CONDITIONER					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Units check				
1	Check alarm code appeared on the remote controller screen before maintenance.				<input type="checkbox"/>
2	Check indoor and outdoor unit for noise and vibration.				<input type="checkbox"/>
3	Check magnetic contactor, electrical capacitor and electrical connections, and then retighten.				<input type="checkbox"/>
4	Check all safe devices.				<input type="checkbox"/>
5	Check leakage of refrigerant on the system.				<input type="checkbox"/>
6	Check state of thermal insulation.				<input type="checkbox"/>
7	Check operation of fans and compressors.				<input type="checkbox"/>
8	Function test of the unit				<input type="checkbox"/>
9	Check operation of all valves (solenoid valve and service valves) and condition of mechanical connection.				<input type="checkbox"/>
10	Check conditions of drain pipe.				<input type="checkbox"/>
11	Check operation of drain pump (if any).				<input type="checkbox"/>
12	Check operation of belt, adjust if necessary				<input type="checkbox"/>
II	Clean and others				
1	Clean the coils of Indoor unit and Outdoor unit by HP water Pump.				<input type="checkbox"/>
2	Clean air filters by water.				<input type="checkbox"/>
3	Clean Condensing water tray, drain pump & drain pipe by HP water pump.				<input type="checkbox"/>
4	Clean electrical box and other parts of the unit by suitable tool.				<input type="checkbox"/>
5	Check state of evaporator and condenser fins. Report to client if necessary				<input type="checkbox"/>
III	Data log				
1	Rated voltage and current.				<input type="checkbox"/>
2	Voltage supply and consumption current of Unit.				<input type="checkbox"/>
4	Measure discharge pressure (if necessary).				<input type="checkbox"/>
5	Measure suction pressure.				<input type="checkbox"/>
6	Measure temperature of air - inlet & outlet at indoor unit.				<input type="checkbox"/>
7	Test electrical insulation of compressor.				<input type="checkbox"/>
IV	Submit maintenance report with recommendation (if any)				<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.11 Variable Refrigerant Volume Air conditioning (VRV)

MAINTENANCE SCOPE OF WORKS FOR VRV AIR CONDITIONER					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Units check				
1	Check alarm code appeared on the remote controller screen before maintenance.			<input type="checkbox"/>	
2	Check indoor and outdoor unit for noise and vibration.			<input type="checkbox"/>	
3	Check magnetic contactor, electrical capacitor and electrical connections, and then retighten.			<input type="checkbox"/>	
4	Check all safe devices.			<input type="checkbox"/>	
5	Check leakage of refrigerant on the system.			<input type="checkbox"/>	
6	Check state of thermal insulation.			<input type="checkbox"/>	
7	Check operation of fans and compressors.			<input type="checkbox"/>	
8	Function test of all indoor units.			<input type="checkbox"/>	
9	Check condition of communication between indoor unit & Outdoor unit, central control.			<input type="checkbox"/>	
10	Check operation of all valves (reversible valve, solenoid valve and service valves) and condition of mechanical connection.			<input type="checkbox"/>	
11	Check conditions of drain pipe.			<input type="checkbox"/>	
12	Check state of evaporator and condenser fins. Report to client if necessary.			<input type="checkbox"/>	
13	Check operation of drain pump (if any).			<input type="checkbox"/>	
II	Clean and others				
1	Clean the coils of Indoor unit and Outdoor unit by HP water Pump.			<input type="checkbox"/>	
2	Clean air filters by water.			<input type="checkbox"/>	
3	Clean Condensing water tray, drain pump & drain pipe by HP water pump.			<input type="checkbox"/>	
4	Clean electrical box and other parts of the unit by suitable tool.			<input type="checkbox"/>	
III	Data log				
1	Rated voltage and current.			<input type="checkbox"/>	
2	Voltage supply and consumption current of compressors.			<input type="checkbox"/>	
4	Measure discharge pressure (if necessary).			<input type="checkbox"/>	
5	Measure suction pressure.			<input type="checkbox"/>	
6	Measure temperature of air - inlet & outlet of indoor unit.			<input type="checkbox"/>	
7	Measure temperature of air - inlet & outlet of outdoor unit.			<input type="checkbox"/>	
8	Test electrical insulation of compressor.			<input type="checkbox"/>	
IV	Submit maintenance report with recommendation (if any)			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.12 Precision Air Conditioning (PAC)

MAINTENANCE SCOPE OF WORKS PRECISION AIR CONDITIONER					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Units check				
1	Check alarm code appeared on the remote controller screen before maintenance.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Check indoor and outdoor unit for noise and vibration.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Check magnetic contactor, electrical capacitor and electrical connections, and then retighten.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Check operation of water level switch, solenoid valve for humidifier: turn ON/OFF properly		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Check operation of electrical heater (reheater)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Check operation of oil heater of compressor		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Check all safe devices.			<input type="checkbox"/>	<input type="checkbox"/>
8	Check leakage of refrigerant on the system.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Check state of thermal insulation.				<input type="checkbox"/>
10	Check operation of fans and compressors.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Function test of the unit		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12	Check operation of all valves (solenoid valve and service valves) and condition of mechanical connection.			<input type="checkbox"/>	<input type="checkbox"/>
13	Check conditions of drain pipe.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14	Check operation of drain pump (if any).		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15	Check operation of belt, adjust if necessary		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
II	Clean and others				
1	Clean the coils of Indoor unit and Outdoor unit by HP water Pump.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Clean air filters by water.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Clean Condensing water tray, drain pump & drain pipe by HP water pump.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Clean electrical box and other parts of the unit by suitable tool.			<input type="checkbox"/>	<input type="checkbox"/>
5	Check state of evaporator and condenser fins. Report to client if necessary				<input type="checkbox"/>
III	Data log				
1	Rated voltage and current.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2	Voltage supply and consumption current of Unit.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4	Measure discharge pressure (if necessary).		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5	Measure suction pressure.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6	Measure temperature of air - inlet & outlet at indoor unit.		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7	Test electrical insulation of compressor.				<input type="checkbox"/>
IV	Submit maintenance report with recommendation (if any)		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

III.1.13 Fire Extinguisher

MAINTENANCE SCOPE OF WORKS FOR FIRE EXTINGUISHER					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Check seals and safety devices to determine if fire extinguisher has been used.			<input type="checkbox"/>	
2	Check body of the fire extinguisher for corrosion or damage.			<input type="checkbox"/>	
3	Test & clean the pipe system connected from fire extinguisher tank to nozzle.			<input type="checkbox"/>	
4	Tighten the bolt on tank's nut, tank's valve also as checking the tightness of the tank and valve.			<input type="checkbox"/>	
5	Test the quality of tank's support stand, tank's hanger, and equipment that spread CO2 powder.			<input type="checkbox"/>	
6	Check and record pressure of fire extinguisher.			<input type="checkbox"/>	
7	Check and record weight of fire extinguisher.			<input type="checkbox"/>	
8	Check quantity & position of fire extinguisher system.			<input type="checkbox"/>	
9	Clean fire extinguisher.			<input type="checkbox"/>	
10	Issue maintenance report with recommendation (if any)			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.14 Fire Fighting

MAINTENANCE SCOPE OF WORKS FOR FIRE FIGHTING SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
A	Born diesel				
I	Engine				
1	Record operated hour meter				<input type="checkbox"/>
2	Record pressure of lubricated oil when operating				<input type="checkbox"/>
3	Record water temp				<input type="checkbox"/>
4	Check for abnormal vibration				<input type="checkbox"/>
5	Check tightness of mountings				<input type="checkbox"/>
6	Check/Clean crankcase breather pipe				<input type="checkbox"/>
7	Clean the engine and the storage				<input type="checkbox"/>
8	Check and replace fuel filter (every 250 hour or 12 months)				<input type="checkbox"/>
II	Lubricating				
1	Check for leaks				<input type="checkbox"/>
2	Check engine oil level (when engine stop)				<input type="checkbox"/>
3	Replace filters (every 250 hour /12 months). Part will be supplied by customer				<input type="checkbox"/>
4	Change engine oil (every 250 hour or 12 months). Parts will be supplied by customer				<input type="checkbox"/>
5	Check and clean sensor oil pressure				<input type="checkbox"/>
6	Clean crankcase heater (if any)				<input type="checkbox"/>
III	Coolant				
1	Check for leaks				<input type="checkbox"/>
2	Check for radiator air restriction				<input type="checkbox"/>
3	Check operation of coolant heater (if any)				<input type="checkbox"/>
4	Check hoses and connections				<input type="checkbox"/>
5	Check water coolant level				<input type="checkbox"/>
6	Check inhibitor concentration				<input type="checkbox"/>
7	Check belt condition & tension				<input type="checkbox"/>
8	Grease fan hub & jockey pulley bearings				<input type="checkbox"/>
9	Clean cooling system				<input type="checkbox"/>
10	Check and clean sensor heater				<input type="checkbox"/>
IV	Induction air				
1	Check for leaks				<input type="checkbox"/>
2	Check inlet air system				<input type="checkbox"/>
3	Check air cleaner restriction				<input type="checkbox"/>
4	Check pipe and connections				<input type="checkbox"/>
5	Replace air cleaner element (after 12 months of use). Part will be supplied by customer				<input type="checkbox"/>
V	Power supply part				
1	Visual check				<input type="checkbox"/>
2	Operation check of Relay				<input type="checkbox"/>
3	Operation check of Delay Relay				<input type="checkbox"/>
4	Lighting check of gas discharge pilot light				<input type="checkbox"/>
5	Check of Solenoid operation voltage and current				<input type="checkbox"/>
6	Operation check of PA for save				<input type="checkbox"/>
7	Tightening check of terminal of cable joint				<input type="checkbox"/>
8	Check of Regulated value of each meter				<input type="checkbox"/>
VI	Pump				
1	Check and inspect of pump for any abnormal noise, vibration.				<input type="checkbox"/>
2	Check for any shaft seal leakage.				<input type="checkbox"/>
3	Check condition of impeller.				<input type="checkbox"/>
4	Lubricate bearing.				<input type="checkbox"/>
5	Check pressure meter and water pressure.				<input type="checkbox"/>
6	Clean pump and pump room.				<input type="checkbox"/>
B	Electric Pump				
I	Pump				
1	Check and inspect of pump for any abnormal noise, vibration.				<input type="checkbox"/>
2	Check for any leakage on piping and connection.				<input type="checkbox"/>
3	Inspection rubber connection.				<input type="checkbox"/>
4	Check for any shaft seal leakage.				<input type="checkbox"/>
5	Check condition of impeller.				<input type="checkbox"/>
6	Check the condition and retighten all connections.				<input type="checkbox"/>
7	Lubricate bearing.				<input type="checkbox"/>
8	Check pressure meter and water pressure.				<input type="checkbox"/>
9	Clean pump and pump room.				<input type="checkbox"/>
II	Motor				
1	Check and inspect of motor for any abnormal noise, vibration or overheating.				<input type="checkbox"/>
2	Lubricate bearing.				<input type="checkbox"/>
3	Winding insulation test by megaom				<input type="checkbox"/>
4	Record running current, compare with rate value.				<input type="checkbox"/>
5	Clean motor.				<input type="checkbox"/>
III	Control panel				
1	Check proper function of control, safety and associated devices.				<input type="checkbox"/>
2	Check security of wires and cables inside panel.				<input type="checkbox"/>
3	Re-tighten terminal, MCB and connections.				<input type="checkbox"/>
4	Clean control panel.				<input type="checkbox"/>
IV	Fire service valve & piping system (Sprinkler, drencher, fire hydrant)				
1	Check for free operation of each valve.				<input type="checkbox"/>
2	Clean, adjust gland packing for leakage.				<input type="checkbox"/>
3	Check the condition and security for all fixing screws.				<input type="checkbox"/>
4	Clean any corrosion and apply touch up rust proof paint (if necessary) – valve only.				<input type="checkbox"/>
5	Check piping system, sprinkler head, valves, for leaking				<input type="checkbox"/>
6	Check tamper switch by closing and opening valve. Send signal to fire alarm panel.(if any)				<input type="checkbox"/>
7	Test fire fighting system.				<input type="checkbox"/>
8	Visual check water pressure at nozzle.				<input type="checkbox"/>
C	Issue report with technical advice (if any).				<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.15 Fresh Water Pump

MAINTENANCE SCOPE OF WORKS FOR FRESH WATER PUMP					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
A	Pump				
1	Check and inspect of pump for any abnormal noise, vibration.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check for any leakage on piping and connection.		<input type="checkbox"/>		<input type="checkbox"/>
3	Inspection rubber connection.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check for any shaft seal leakage.				<input type="checkbox"/>
5	Check condition of impeller.		<input type="checkbox"/>		<input type="checkbox"/>
6	Check the condition and retighten all connections.		<input type="checkbox"/>		<input type="checkbox"/>
7	Lubricate bearing.				<input type="checkbox"/>
8	Check pressure meter and water pressure.		<input type="checkbox"/>		<input type="checkbox"/>
9	Clean pump and pump room.		<input type="checkbox"/>		<input type="checkbox"/>
B	Motor				
1	Check and inspect of motor for any abnormal noise, vibration or overheating.		<input type="checkbox"/>		<input type="checkbox"/>
2	Lubricate bearing.				<input type="checkbox"/>
3	Winding insulation test by megaom				<input type="checkbox"/>
4	Record running current, compare with rate value.		<input type="checkbox"/>		<input type="checkbox"/>
5	Clean motor.		<input type="checkbox"/>		<input type="checkbox"/>
C	Control panel				
1	Check proper function of control, safety and associated devices.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check security of wires and cables inside panel.		<input type="checkbox"/>		<input type="checkbox"/>
3	Re-tighten terminal, MCB and connections.		<input type="checkbox"/>		<input type="checkbox"/>
4	Clean control panel.		<input type="checkbox"/>		<input type="checkbox"/>
D	Issue report with technical advice (if any).		<input type="checkbox"/>		<input type="checkbox"/>

III.1.16 Sum Pump

MAINTENANCE SCOPE OF WORKS FOR SUM PUMP					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Check and inspect of system for any abnormal noise, vibration.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check the pump drain line for damage or blockage.		<input type="checkbox"/>		<input type="checkbox"/>
3	Check proper function of elec. control, safety and associated devices.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check water flow on drain pipe (if any).		<input type="checkbox"/>		<input type="checkbox"/>
5	Re-tighten terminal, MCB Main breaker in and out going.		<input type="checkbox"/>		<input type="checkbox"/>
6	Vacuum clean motor starter panel.		<input type="checkbox"/>		<input type="checkbox"/>
7	Check security of wires and cables inside panel.		<input type="checkbox"/>		<input type="checkbox"/>
8	Check earthing system at panel.		<input type="checkbox"/>		<input type="checkbox"/>
9	Winding insulation test by megaom				<input type="checkbox"/>
10	Fuction test for sum pump		<input type="checkbox"/>		<input type="checkbox"/>
11	Record running amperes, voltage compare and against rated figure.		<input type="checkbox"/>		<input type="checkbox"/>
12	Issue report with technical advice (if any).		<input type="checkbox"/>		<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.17 Wastewater Treatment

MAINTENANCE SCOPE OF WORKS FOR WASTE WATER TREATMENT SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I Air Blowers					
1	Check for any abnormal vibration, overheating, noise or smell.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check and tighten electrical and mechanical connections.				<input type="checkbox"/>
3	Measure insulation.				<input type="checkbox"/>
4	Measure current when the air blower in operation.		<input type="checkbox"/>		<input type="checkbox"/>
5	Measure voltage when air blower in operation.		<input type="checkbox"/>		<input type="checkbox"/>
6	Check air diffusers for damages and blockage.		<input type="checkbox"/>		<input type="checkbox"/>
7	Dismantle and clean the suction pipe, air silencer.		<input type="checkbox"/>		<input type="checkbox"/>
8	Check oil level, oil quality and replace if necessary. (oil supply by client)				<input type="checkbox"/>
9	Check drives and controls as in good condition and function.		<input type="checkbox"/>		<input type="checkbox"/>
10	Check pressure gauge of air blower		<input type="checkbox"/>		<input type="checkbox"/>
11	Check and lubricate for oil, greasing (if necessary).		<input type="checkbox"/>		<input type="checkbox"/>
II Piping					
1	Check for damages, leaks, clogs and completeness.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check and clean air pipes.		<input type="checkbox"/>		<input type="checkbox"/>
III Tank/ Pump pits/ Containers					
1	Inspect humus tank and note visual appearance of final effluent and absence (or otherwise) of sludge build up.				<input type="checkbox"/>
2	Pick up garbage and clean anti-garbage Mesh or Cages.		<input type="checkbox"/>		<input type="checkbox"/>
3	Check water level of chemical tank and mixing new chemical if needed.		<input type="checkbox"/>		<input type="checkbox"/>
4	Check for leaks, water proofing, lining material.		<input type="checkbox"/>		<input type="checkbox"/>
5	Grease all bearing & chain couplings through nipples (if necessary).				<input type="checkbox"/>
6	Run each pump and observe any abnormal noise.		<input type="checkbox"/>		<input type="checkbox"/>
7	Check proper function of elec. control, safety and associated devices.		<input type="checkbox"/>		<input type="checkbox"/>
8	Re-tighten terminal, MCB, Main breaker.				<input type="checkbox"/>
9	Perform and record insulation test to the motor winding insulation.		<input type="checkbox"/>		<input type="checkbox"/>
10	Record running amperes, voltage compare against rated figure.		<input type="checkbox"/>		<input type="checkbox"/>
11	Remove sludge (not included the quotation)				<input type="checkbox"/>
IV Mixer, Chemical pump					
1	Check aeration motor overheating.		<input type="checkbox"/>		<input type="checkbox"/>
2	Perform and record insulation test to the motor winding insulation.		<input type="checkbox"/>		<input type="checkbox"/>
3	Record running amperes, voltage compare against rated figure.		<input type="checkbox"/>		<input type="checkbox"/>
VI Electric box & Control panel					
1	Check security of wires and cables inside panel.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check for any abnormal noise or overheating.		<input type="checkbox"/>		<input type="checkbox"/>
3	Check earth system at panel.		<input type="checkbox"/>		<input type="checkbox"/>
4	Vacuum clean motor starter panel.		<input type="checkbox"/>		<input type="checkbox"/>
VII Analyze the quality of waste water after treatment					
1	Test parameters as complying with Vietnamese Standard QCVN 40:2011- BTNMT.				<input type="checkbox"/>
Report with technical advice (if any)					
VIII Báo cáo và khuyến cáo kỹ thuật (nếu có)					
STANDARD OF WATER TESTING					
No	Parameter		Unit	Standard	
1	PH	-	-	5-Sep	
2	BOD ₅	Mg/l	Mg/l	≤50	
3	TSS	Mg/l	Mg/l	≤100	
4	Total dissolved solid	Mg/l	Mg/l	≤1000	
5	Sulfua	Mg/l	Mg/l	≤4	
6	Amoni	Mg/l	Mg/l	≤10	
7	Nitrat	Mg/l	Mg/l	≤ 50	
8	Lipit	Mg/l	Mg/l	≤ 20	
9	Surface activity material		Mg/l	≤ 10	
10	Phosphat	Mg/l	Mg/l	≤ 10	
11	Total Coliform	MPN/100 ml	MPN/100 ml	≤ 5.000	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.18 Heat pump

MAINTENANCE SCOPE OF WORKS FOR HEATPUMP					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Units check				
1	Check unit for noise and vibration.		<input type="checkbox"/>		
2	Check magnetic contactor, capacitor and electrical connections, and then retighten.		<input type="checkbox"/>		
3	Check all safe devices.		<input type="checkbox"/>		
4	Check leakage of refrigerant on the system. More charge or readjust.		<input type="checkbox"/>		
5	Check state of thermal insulation.		<input type="checkbox"/>		
6	Check operation condition of heatpump & circulating pump.		<input type="checkbox"/>		
7	Check any corrosion & touchup painting.		<input type="checkbox"/>		
8	Check state of heat exchanger.		<input type="checkbox"/>		
9	Check proper operation of thermal sensors.		<input type="checkbox"/>		
10	Check condition of flow switch.		<input type="checkbox"/>		
II	Clean and others				
1	Clean the coils of evaporator by HP water Pump.		<input type="checkbox"/>		
2	Clean electrical box by suitable tool.		<input type="checkbox"/>		
3	Clean other component by suitable tool.		<input type="checkbox"/>		
III	Data log				
1	Rated current and voltage.		<input type="checkbox"/>		
2	Consumption voltage and current.		<input type="checkbox"/>		
3	Measure Suction & discharge pressure (if necessary).		<input type="checkbox"/>		
4	Measure temperature of water inlet & outlet at condenser.		<input type="checkbox"/>		
5	Measure temperature of air inlet & outlet at evaporator.		<input type="checkbox"/>		
6	Test electrical insulation of compressor. (If necessary)		<input type="checkbox"/>		
IV	Submit maintenance report with recommendation (if any)		<input type="checkbox"/>		

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.19 Ventilation Fan

MAINTENANCE SCOPE OF WORKS FOR VENTILATION FAN					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Units check				
1	Check noise and vibration of fan.			<input type="checkbox"/>	
2	Check electrical connections, Flexible connections.			<input type="checkbox"/>	
II	Clean and others				
1	Clean casing, fan and fan motor.			<input type="checkbox"/>	
2	Clean Insect catching nets (if any)			<input type="checkbox"/>	
3	Clean all air filters.			<input type="checkbox"/>	
4	Clean other part by suitable tool.			<input type="checkbox"/>	
5	Lubricate fan motor bearings (if any).			<input type="checkbox"/>	
III	Data log				
1	Check rated current and voltage.			<input type="checkbox"/>	
2	Measure current of Fan motor.			<input type="checkbox"/>	
3	Measure voltage supply.			<input type="checkbox"/>	
4	Check state of electrical insulation of motor windings.			<input type="checkbox"/>	
IV	Submit maintenance report with recommendation (if any)			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.20 Access Control

MAINTENANCE SCOPE OF WORK FOR ACCESS CONTROL SYSTEM (ACS)					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
A	Access workstation				
1	Check operation status Hardware of workstation			<input type="checkbox"/>	
2	Check operation status Software of workstation			<input type="checkbox"/>	
3	Check function of system (function in use)			<input type="checkbox"/>	
4	Check system alarm, after that clear it or inform solution to clear it			<input type="checkbox"/>	
5	Make backup of software before maintenance			<input type="checkbox"/>	
6	Cleaning equipments			<input type="checkbox"/>	
B	Main Controller Panel (if have)				
1	Check the function & status of main controller			<input type="checkbox"/>	
2	Check communication links between main controller and work station			<input type="checkbox"/>	
3	Check communication links between main controller and local controller			<input type="checkbox"/>	
4	Check the output voltage of power adaptor			<input type="checkbox"/>	
5	Check the back-up battery of controller by shutting down main supply			<input type="checkbox"/>	
6	Cleaning equipments			<input type="checkbox"/>	
C	Door Controller Panel				
1	Check the function & status of card access controller			<input type="checkbox"/>	
2	Check communication links between card readers and main controller (or workstation)			<input type="checkbox"/>	
4	Check the output voltage of power adaptor			<input type="checkbox"/>	
5	Check the back-up battery of controller by shutting down main supply			<input type="checkbox"/>	
7	Cleaning equipments			<input type="checkbox"/>	
D	Field Device				
1	Visual check status of card reader: Possion, sensibility			<input type="checkbox"/>	
2	Check function of card reader with a valid card and invalid card			<input type="checkbox"/>	
3	Visual check operation status of electromagnetic lock or electrical lock			<input type="checkbox"/>	
4	Visual check operation status of Emergency button (if have)			<input type="checkbox"/>	
5	Visual check operation status of door contacts			<input type="checkbox"/>	
6	Check the function & status of flap barrier (if have)			<input type="checkbox"/>	
7	Cleaning equipments			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.21 Fire Alarm

MAINTENANCE SCOPE OF WORKS FOR FIRE ALARM SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Visual checking the main panel for damage, alarm on the panel, cable defect, loosing connection.			<input type="checkbox"/>	
2	Measuring batteries voltage, internal resistance of each batteries.			<input type="checkbox"/>	
3	Check operation of batteries charger.			<input type="checkbox"/>	
4	Turn off electric power supply to test operation of fire alarm system by battery in 10 minute			<input type="checkbox"/>	
5	Check the buzzer of main panel.			<input type="checkbox"/>	
6	Check the led light of main panel.			<input type="checkbox"/>	
7	Check function of manual call point on each floor.			<input type="checkbox"/>	
8	Checking bell on each floor.			<input type="checkbox"/>	
9	Cleaning in/ outside the panel.			<input type="checkbox"/>	
10	Manual alarm test for the alarm system.			<input type="checkbox"/>	
11	Automatic alarm test for the alarm system.			<input type="checkbox"/>	
12	Check and clean heat detectors and smoke			<input type="checkbox"/>	
13	Random test for fire alarm system by smocke detector & heat detector			<input type="checkbox"/>	
14	Interlock test fire alarm system with others system (if any)			<input type="checkbox"/>	
15	Issue an auditing report on the system.			<input type="checkbox"/>	

III.1.22 Public Address

MAINTENANCE SCOPE OF WORK FOR PUBLIC ADDRESS SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
A	Public address				
1	Cleaning main panel & amplify with suitable cloth – Adjusted the volume if require			<input type="checkbox"/>	
2	Check the power cable connector of amplifies system.			<input type="checkbox"/>	
3	Clean & tighten connection for cable of speaker			<input type="checkbox"/>	
4	Checking the voltage signal and current of loudspeaker to find problem			<input type="checkbox"/>	
5	Clean cover of all speakers			<input type="checkbox"/>	
6	Check quality sound of each loudspeaker			<input type="checkbox"/>	
B	Intercom system				
1	Check operation of microphone			<input type="checkbox"/>	
2	Check the sound quality of the speakers, amplifier by music			<input type="checkbox"/>	
3	Function test for P/A system			<input type="checkbox"/>	

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.23 FM 200 & CO2

MAINTENANCE SCOPE OF WORKS FOR FM 200, NN 100, CO2					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Visual checking the control panel for damage, alarm on the panel, cable defect, losing connection.			<input type="checkbox"/>	
2	Measuring batteries voltage.			<input type="checkbox"/>	
3	Measuring voltage of batteries charger and check battery alarm indication.			<input type="checkbox"/>	
4	Test batteries and specific gravity of electrolyte.			<input type="checkbox"/>	
5	Checking the buzzer of main panel.			<input type="checkbox"/>	
6	Checking the led light of main panel.			<input type="checkbox"/>	
7	Checking the bells & horns of main panel.			<input type="checkbox"/>	
8	Test speakers.			<input type="checkbox"/>	
9	Verify monitoring connection.			<input type="checkbox"/>	
10	Inspect annunciator.			<input type="checkbox"/>	
11	Check smoke detector sensitivity.			<input type="checkbox"/>	
12	Check duct detectors.			<input type="checkbox"/>	
13	Check thermal detectors.			<input type="checkbox"/>	
14	Test flow switches.			<input type="checkbox"/>	
15	Check valves.			<input type="checkbox"/>	
16	Check piping.			<input type="checkbox"/>	
17	Check pressure of cylinder, actuating cylinder.			<input type="checkbox"/>	
18	Check ground fault detection circuitry.			<input type="checkbox"/>	
19	Cleaning in/ outside the panel.			<input type="checkbox"/>	
20	Detectors cleaned.			<input type="checkbox"/>	
21	Issue report and advice (if any).			<input type="checkbox"/>	

III.1.24 Telephone

MAINTENANCE SCOPE OF WORK FOR TELEPHONE SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Switchboard				
1	Cleaning equipment and main parts.			<input type="checkbox"/>	
2	Re-arrange the main cable (if possible).			<input type="checkbox"/>	
3	Check general engine room systems and machinery together with the accessories accompanying equipment, including inspection immediately the whole system hardware.			<input type="checkbox"/>	
II	Telephone				
1	Clean & check all terminal connection			<input type="checkbox"/>	
III	Make report with advice (if any)			<input type="checkbox"/>	

III.1.25 Roller Shutter door

MAINTENANCE SCOPE OF WORKS FOR ROLLER SHUTTER DOOR SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
1	Check smooth operation (up and down) of the shutter.		<input type="checkbox"/>		<input type="checkbox"/>
2	Check proper function of the micro-switches.		<input type="checkbox"/>		<input type="checkbox"/>
3	Check manual operation device.		<input type="checkbox"/>		<input type="checkbox"/>
4	Lubricate bearings, gears and all lub points.		<input type="checkbox"/>		<input type="checkbox"/>
5	Measure motor voltage and current		<input type="checkbox"/>		<input type="checkbox"/>
6	Carry out insulation test to motor winding insulation (yearly).				<input type="checkbox"/>
7	Clean and remove dust at motor, gear and guard rail.		<input type="checkbox"/>		<input type="checkbox"/>
8	Clean and descale any grease, dust, rust and apply touch up rust proof painting.				<input type="checkbox"/>
9	Issue report and advices (if any).		<input type="checkbox"/>		<input type="checkbox"/>

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



III.1.26 Liquefied Petroleum Gas

MAINTENANCE SCOPE OF WORKS FOR LPG SYSTEM					
No	Description of work	Routine			
		Monthly	Quarterly	Semi yearly	Yearly
I	Visual Inspection				
1	Examine room ventilation			<input type="checkbox"/>	
2	Ensure clear access to plant and equipment			<input type="checkbox"/>	
3	Check for abnormal smells.			<input type="checkbox"/>	
II	Piping				
1	Check for corrosion and damage			<input type="checkbox"/>	
2	Ensure that terminals are not blocked or obstructed			<input type="checkbox"/>	
3	Clean piping system if necessary			<input type="checkbox"/>	
4	Examine for leaking on the system			<input type="checkbox"/>	
III	Kitchen equipments				
1	Check gas leak at connecting point from gas pipe to Kitchen equipment.			<input type="checkbox"/>	
IV	Safety device				
1	Check operation condition of pressure reducing valve, safety valve			<input type="checkbox"/>	
2	Test the system's gas leak protection function			<input type="checkbox"/>	
IV	Submit maintenance report with recommendation (if any)			<input type="checkbox"/>	

III.2 PREVENTIVE MAINTENANCE PROGRAM

Preventive maintenance generally refers to routine inspections, adjustments, lubrication and cleaning of fixed and movable equipment, machinery and appliances utilised in the daily operation of a facility.

Performing regular routine preventive maintenance keeps equipment in good running order, reducing the possibility of equipment failure thus insuring and extending expected equipment life. Through regular preventive maintenance, potential problems can be detected early thus reducing time and preventing more expensive repairs.

The supervisor of performance of routine preventive maintenance in Campus is the responsibility of Asset Management. The following document is designed to give building supervisors the guidance necessary to perform basic routine preventive maintenance checks and tasks. These checks are to be performed throughout the campus building, both interior and exterior, including the grounds. The preventive maintenance duties incorporated in this package are an expected function of Asset Management supervisor's normal duties.

The enclosed P.M. program provides an outline and checklist of the items to be inspected and performed by the Technical Team. The frequency that the items are to be checked, and the procedures required for each item are also detailed in the program.

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



Check sheets are provided for daily, weekly, monthly, quarterly and annual preventive maintenance tasks.

It is the responsibility of Asset Management to see that these preventive maintenance tasks are performed and properly recorded on the appropriate check sheet. The original check sheet shall be posted at a visible location in the technical office. Completed reports shall be forwarded to the Facilities Manager by every Mondays. The reports expected at that time include the daily, weekly and monthly check sheets.

The quarterly and annual check sheets are to be forwarded by the 10th of the month following the conclusion of the performance period.

Problems found during the preventive maintenance inspections should be noted in the inspector's comments section on each check sheet. Problems that cannot be repaired by the in-house technician should be reported to the Facilities Manager, or by telephone if considered an emergency.

Check sheets require either a visual inspection, a specific task to be performed or the recordation of information. Most of the routine inspections are primarily visual inspections that should be incorporated into the Facilities Supervisor's daily travels throughout the campus facility.

CAMPUS PREVENTIVE MAINTENANCE PROGRAM		
No	PROGRAM	Frequency
1. Medium voltage system		
1.1	Daily preventive maintenance as designated checklist	Daily
1.2	Cleaning	Monthly
2. Substation system		
2.1	Daily preventive maintenance as designated checklist	Daily
3. Low voltage system		
3.1	Daily preventive maintenance as designated checklist	Daily
3.2	Cleaning	Monthly
4. Generator system		
4.1	Daily preventive maintenance as designated checklist	Daily
4.2	Periodic test run without load	Weekly
4.3	Cleaning	Monthly

**ASSET MANAGEMENT
DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



4.4	Periodic test run with load (75%)	Quarterly
5. Room for pumping water for domestic use and fire prevention		
5.1	Daily preventive maintenance as designated checklist	Daily
5.2	Test run the fire protection pump periodically	Weekly
5.3	Check the equipment inside the electrical cabinet periodically	Monthly
5.4	Clean the surface of electrical cabinets, pump control cabinets, clean walls and ceilings	Monthly
5.5	Check the equipment inside the electrical cabinet periodically	Monthly
6. Rainwater pumping room		
6.1	Daily preventive maintenance as designated checklist	Daily
6.2	Check the equipment inside the electrical cabinet periodically	Monthly
6.2	Cleaning the rainwater pump room	Monthly
7. Landscape lighting system		
7.1	Check outdoor lighting equipment (damaged, burned out)	Daily
7.2	Check the outdoor lighting electrical cabinet system according to the checklist	Daily
7.3	Clean and check electrical cabinets periodically	Weekly
8. System of technical rooms (Electrical engineering room, light electricity, network room ...)		
8.1	Periodically check the status of the electrical engineering room	Weekly
8.2	Cleaning the technical rooms	Monthly
9. Aquarium system		
9.1	Daily preventive maintenance as designated checklist	Daily
9.2	Clean the surface of the tank: pick up trash on the surface, bottom of the tank, push moss ...	Daily
9.3	Periodically clean the bottom of the tank: vacuum the bottom of the tank	Weekly
9.4	Clean the surface of electrical cabinets, pump control cabinets, clean walls and ceilings	Monthly
9.5	Periodic repair: redo tiles, patching, plastering...	Yearly
10. Air conditioning system		
10.1	Daily preventive maintenance as designated checklist	Daily

ASSET MANAGEMENT**DEPARTMENT**

BUV's Facilities Management
Policy and Procedure

Doc. Ref.:012022/POLICY/BUV-ASD
Approved by: Chief Operating Officer
Approved Date: 17 December 2021
Effective Date: 1 January 2022
Version No: 1.1



10.2	Cleaning the cold side of the air conditioner: cleaning according to actual inspection	Up to actual inspection
11. Kitchen exhaust fan system, exhaust system		
11.1	Daily preventive maintenance as designated checklist	Daily
12. Data centre area		
12.1	Daily preventive maintenance as designated checklist	Daily
13. Equipment, facilities, other items		
13.1	Periodic preventive maintenance as designated checklist	Weekly
14. CCTV room		
14.1	Daily preventive maintenance PA system as designated checklist	Daily
14.2	Daily preventive maintenance CCTV system as designated checklist	Daily
14.3	Daily preventive maintenance Access Control system as designated checklist	Daily
14.4	Daily preventive maintenance Panic system as designated checklist	Daily
14.5	Daily preventive maintenance Central fire alarm system system as designated checklist	Daily
14.5	Periodic cleaning of surfaces	Monthly